

Air Cleaner Test Report

Applicant : RHT Industries Limited

Address : Block B, 2/F, Goodwill Industrial Building, No. 36-44 Pak Tin Par
Street, Tsuen Wan, New Territories, Hong Kong

Report Number : REPAP20050701

Report Issue Date : 08 May 2020

Total Page : 8 pages (including this page)

This document is issued by the Company under its General Conditions of Service printed overleaf. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any reader of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30days only. This document cannot be reproduced except in full, without prior approval of the Company.

TABLE OF CONTENT

1. Sample Description	3
2. Detail Description of the sample(s)	4 – 5
3. Result of Bacteria Removal Efficiency	6 – 7
4. Result of Virus Removal Efficiency	8


1. Sample Description

Product	: Air Cleaner
Brand Name	: b-MOLA
Model(s)	: IA60
No. of Sample Received	: 1
Test Date	: 01 Dec 2019
Test Standard(s)	GB 21551.3-2020
Test Item(s)	: 1. Bacteria Removal Efficiency <ul style="list-style-type: none">- Staphylococcus Albus (8032)- Staphylococcus Aureus (ATCC 6538) 2. Virus Removal Efficiency <ul style="list-style-type: none">- Bacteriophage (Phi-X174)
Test Result	: See the attached sheets
Remark	: This report refers to test report published by Guang Zhou Institute of Microbiology (Report Number: KY20190134) Client claimed that model IA60 same as BM300. Only difference is the selling platform.

2. Detail Description of the sample(s)



b-MOLA/IA60



NCCO Reactor and Normal White HEPA



3. Result of Bacteria Removal Efficiency

Test Duration (min)		Bacteria Under Test		
60		Staphylococcus Albus (8032)		
Reference Group				
Sample Number	Initial Average Bacteria Conc.	Final Average Bacteria Conc.	Natural Decay Rate	
	V_0 (cfu/m ³)	V_t (cfu/m ³)	(%)	
1	1.22×10^5	1.00×10^5	18.03	
2	1.35×10^5	1.10×10^5	18.52	
3	1.20×10^5	9.93×10^4	17.25	
Test Group				
Sample Number	Initial Average Bacteria Conc.	Final Average Bacteria Conc.	Removal Efficiency	
	V_1 (cfu/m ³)	V_2 (cfu/m ³)	(%)	
1	1.24×10^5	7	99.99	
2	1.28×10^5	7	99.99	
3	1.23×10^5	7	99.99	
Average			99.99	

Remark

1. For detail test procedure, please refer to the original test report published by Guang Zhou Institute of Microbiology.
2. Removal efficiency have already considered the natural decay of specified bacteria.



Test Duration (min)		Bacteria Under Test		
60		Staphylococcus Aureus (ATCC 6538)		
Reference Group				
Sample Number	Initial Average Bacteria Conc.	Final Average Bacteria Conc.	Natural Decay Rate	
	V_0 (cfu/m ³)	V_t (cfu/m ³)	(%)	
1	1.05×10^5	8.80×10^4	16.19	
2	1.11×10^5	9.38×10^4	15.50	
3	1.03×10^5	8.56×10^4	16.89	
Test Group				
Sample Number	Initial Average Bacteria Conc.	Final Average Bacteria Conc.	Removal Efficiency	
	V_1 (cfu/m ³)	V_2 (cfu/m ³)	(%)	
1	1.07×10^5	7	99.99	
2	1.16×10^5	7	99.99	
3	9.94×10^4	7	99.99	
Average			99.99	

Remark

1. For detail test procedure, please refer to the original test report published by Guang Zhou Institute of Microbiology.
2. Removal efficiency have already considered the natural decay of specified bacteria.

4. Result of Virus Removal Efficiency

Test Duration (min)		Virus Under Test		
60		Bacteriophage (Phi-X174)		
Reference Group				
Sample Number	Initial Average Virus Conc.	Final Average Virus Conc.	Natural	
	V_0 (pfu/m ³)	V_t (pfu/m ³)	Decay Rate (%)	
1	1.23×10^5	9.25×10^4	24.80	
2	1.29×10^5	9.90×10^4	23.26	
3	1.21×10^5	9.23×10^4	23.72	
Test Group				
Sample Number	Initial Average Virus Conc.	Final Average Virus Conc.	Removal	
	V_1 (pfu/m ³)	V_2 (pfu/m ³)	Efficiency (%)	
1	1.26×10^5	7	99.99	
2	1.33×10^5	7	99.99	
3	1.15×10^5	7	99.99	
Average			99.99	

Remark

- For detail test procedure, please refer to the original test report published by Guang Zhou Institute of Microbiology.
- Removal efficiency have already considered the natural decay of specified virus.

*** End of Report ***